

EXHIBIT A TO OFFER TO PURCHASE -- CITY OF MILWAUKEE SCOPE OF WORK

Scope of Work for Property Located at: 3237-39 North 23rd Street

Property is: Single Family ☐ Duplex ☒ Other ☐

Date: 2/26/2018 **OCCUPIED** ☐ **VACANT** ☒

City prepared this Scope upon visual inspection only, for limited purpose. City does not warrant content or conclusions, and is not responsible for errors, omissions, or discovery of conditions that are or may constitute defects or concerns

ESSENTIAL REPAIRS. All buyers must complete Essential Repairs and obtain "Essential Repair Verification Form" and provide same to DCD within 180 days of City's deed to buyer in order to get return of performance deposit.

| Location | Required Work | Note/Comments | Cost | |
|-----------------|--------------------------------|--|------|--------------------------------|
| Entire Building | Structural Violations | n/a <input type="checkbox"/> Yes <input type="checkbox"/> | \$ | |
| | | <input type="checkbox"/> <input checked="" type="checkbox"/> Both furnaces in standing water. Service or replace as req'd to restore proper operation. Permits req'd if replacing. | \$ | 6,200.00 |
| | Defective/Missing HVAC | n/a <input type="checkbox"/> Yes <input type="checkbox"/> | \$ | |
| | | <input type="checkbox"/> <input checked="" type="checkbox"/> Leaks in basement, significant standing water. Both water heaters improperly installed. Repair or replace water heaters and fix leaking supply pipes. Permits req'd for all work. | \$ | 3,500.00 |
| | Defective/Missing Plumbing | n/a <input type="checkbox"/> Yes <input type="checkbox"/> | \$ | |
| | Defective/Missing Electrical | n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Exposed wires @ old panel box - permanently close. | \$ | 50.00 |
| | Defective/Missing Egress | n/a <input type="checkbox"/> Yes <input type="checkbox"/> | \$ | |
| | Defective/Missing Smoke Alarm | n/a <input type="checkbox"/> Yes <input type="checkbox"/> | \$ | |
| | Defective/Missing CO Alarm | n/a <input type="checkbox"/> Yes <input type="checkbox"/> | \$ | |
| | Defective/Missing Roof (Major) | n/a <input type="checkbox"/> Yes <input type="checkbox"/> | \$ | |
| | Missing Window(s) | n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Several units missing or severely damaged - house not weathertight. | \$ | 3,500.00 |
| | Missing Exterior Door(s) | n/a <input type="checkbox"/> Yes <input type="checkbox"/> | \$ | |
| | Other | n/a <input type="checkbox"/> Yes <input type="checkbox"/> | \$ | |
| | | | | Essential Repairs Total |
| | | | | 13,250.00 |

OTHER REPAIRS (Exterior & Interior). Buyer is notified that the following are code violations that must be addressed and are subject to Department of Neighborhood Services (DNS) enforcement.

Exterior Condition Report

| Location | Required Work | Note/Comments | Cost |
|----------|------------------------------|--|-------------|
| Site | Landscaping | n/a <input type="checkbox"/> Yes <input type="checkbox"/> | \$ |
| | Steps/Handrails | n/a <input type="checkbox"/> Yes <input type="checkbox"/> | \$ |
| | Service walks | n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> | \$ 1,500.00 |
| | Fencing | n/a <input type="checkbox"/> Yes <input type="checkbox"/> | \$ |
| | Parking | n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> | \$ 4,000.00 |
| | Retaining walls | n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> | \$ 1,500.00 |
| | Other | n/a <input type="checkbox"/> Yes <input type="checkbox"/> | \$ |
| | Other | n/a <input type="checkbox"/> Yes <input type="checkbox"/> | \$ |
| | Singles: repair | n/a <input checked="" type="checkbox"/> Yes <input type="checkbox"/> | \$ |
| | Shingles: Roof over existing | n/a <input checked="" type="checkbox"/> Yes <input type="checkbox"/> | \$ |
| Garage | Shingles:Tear off & re-roof | n/a <input checked="" type="checkbox"/> Yes <input type="checkbox"/> | \$ |
| | Gutters/downspouts | n/a <input checked="" type="checkbox"/> Yes <input type="checkbox"/> | \$ |
| | Flashing | n/a <input checked="" type="checkbox"/> Yes <input type="checkbox"/> | \$ |
| | Eaves | n/a <input checked="" type="checkbox"/> Yes <input type="checkbox"/> | \$ |
| | Siding | n/a <input checked="" type="checkbox"/> Yes <input type="checkbox"/> | \$ |
| | Doors | n/a <input checked="" type="checkbox"/> Yes <input type="checkbox"/> | \$ |
| | Windows | n/a <input checked="" type="checkbox"/> Yes <input type="checkbox"/> | \$ |
| | Slab | n/a <input checked="" type="checkbox"/> Yes <input type="checkbox"/> | \$ |
| | Paint | n/a <input checked="" type="checkbox"/> Yes <input type="checkbox"/> | \$ |
| | | Page 1 of 7 | |

| | | | | | | |
|------------------------------|-----------------|---------|-------------------------------------|--------------------------|-------------------------------------|--|
| Garage (Cont) | Electrical | n/a | <input checked="" type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| | Other | n/a | <input checked="" type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Porches | Roof | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | Flat roof on upper front porch leaking \$ 2,500.00 |
| | Deck-upper | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| | Deck-lower | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| | Steps/handrails | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| | Ceiling | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ 250.00 |
| | Guardrails | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | North side of front steps \$ 400.00 |
| | Structural | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| | Paint | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| | Other | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| | House | Chimney | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> |
| Shingles: repair | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Shingles: Roof over existing | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Shingles:Tear off & re-roof | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Gutters/downspouts | | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ 1,050.00 |
| Flashing | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Eaves | | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ 900.00 |
| Siding | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Storm Doors | | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ 500.00 |
| Prime ("main") Doors | | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ 700.00 |
| Storm Windows | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Prime ("main") Windows | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Paint | | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ 1,500.00 |
| Foundation | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Electrical | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Other | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Other | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Other | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Other | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |

Exterior: Estimated Cost:* \$ 28,050.00

*average contracted cost. Actual costs may vary. Self help will reduce the amount.

Interior Condition Report

Unit: Entire unit (single family) ☐
Upper unit of duplex ☐

Lower unit of duplex ☒
Other ☐

Mechanical Heating

Required Work

| | | | | | |
|-------------------------------------|-----|--------------------------|-----|-------------------------------------|------------------------------|
| Repair/replace boiler | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Repair radiation | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Repair/replace furnace | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | See essential repairs |
| Repair ductwork | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Replace thermostat | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Repair/replace grilles | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ 250.00 |
| Tune boiler/furn. insp ht exchanger | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |

Electrical

| | | | | | |
|------------------------------|-----|--------------------------|-----|-------------------------------------|------------------|
| Repair/replace receptacles | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ 300.00 |
| Repair/replace switches | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ 300.00 |
| Repair/replace fixtures | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ 300.00 |
| Install outlets and circuits | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Install outlets and circuits | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Install outlets and circuits | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Install outlets and circuits | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Upgrade service | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Other | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | Permit |
| | | | | | \$ 90.00 |
| Other | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |

Plumbing

| | | | | | |
|------------------------------------|-----|--------------------------|-----|-------------------------------------|---|
| Repair/replace kitchen sink | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Repair/replace kitchen sink faucet | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Repair/replace tub | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Repair/replace tub faucet | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Repair/replace toilet | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Repair/replace lavatory | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Repair/replace lavatory faucet | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Repair/replace wash tub | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Repair/replace wash tub faucet | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Unclog piping: | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Repair drain/waste/vent piping | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | Drain pipes under kitchen & bath sinks |
| | | | | | \$ 600.00 |
| Repair water piping | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Repair/replace water heater | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Other | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | See essential repairs |
| | | | | | \$ |
| Other | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |

| | | | | | | | |
|----------------------------------|----------------------------------|-----|--------------------------|-----|-------------------------------------|----|-----------------|
| Windows | Replace broken glass | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| | Repair or replace sash | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Doors | Repair or replace doors | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 600.00 |
| | Repair or repl. locks/latches | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 75.00 |
| Walls/Ceilings | Repair or repl. @ defective | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 2,000.00 |
| Paint | Repair or repl. @ defective | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 1,000.00 |
| Fire Safety | Install smoke/CO alarm:bsmt. | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 75.00 |
| | Install smoke/CO alarm: 1st flr. | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 75.00 |
| | Install smoke/CO alarm: 2nd flr. | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Handrails | Repair/replace defective | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 200.00 |
| Stairs | Repair defective | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Floors | Repair defective | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 1,500.00 |
| Other | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| | | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Interior: Estimated Cost: | | | | | | \$ | 7,365.00 |

Interior Condition Report

Unit: Entire unit (single family) ☐
Upper unit of duplex ☒

Lower unit of duplex ☐
Other ☐

Mechanical Heating

Required Work

| | | | | | |
|-------------------------------------|-----|--------------------------|-----|-------------------------------------|--------------------------|
| Repair/replace boiler | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Repair radiation | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Repair/replace furnace | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | See essential repairs \$ |
| Repair ductwork | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Replace thermostat | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Repair/replace grilles | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
| Tune boiler/furn. insp ht exchanger | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |

Electrical

| | | | | | | |
|------------------------------|-----|--------------------------|-----|-------------------------------------|----|--------|
| Repair/replace receptacles | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 300.00 |
| Repair/replace switches | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 300.00 |
| Repair/replace fixtures | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 300.00 |
| Install outlets and circuits | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Install outlets and circuits | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Install outlets and circuits | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Install outlets and circuits | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Upgrade service | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Other | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 90.00 |
| Other | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |

Plumbing

| | | | | | | |
|------------------------------------|-----|--------------------------|-----|-------------------------------------|--------------------------|--------|
| Repair/replace kitchen sink | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Repair/replace kitchen sink faucet | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Repair/replace tub | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Repair/replace tub faucet | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Repair/replace toilet | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 350.00 |
| Repair/replace lavatory | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Repair/replace lavatory faucet | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Repair/replace wash tub | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Repair/replace wash tub faucet | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Unclog piping: | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Repair drain/waste/vent piping | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Repair water piping | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Repair/replace water heater | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Other | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ | |
| Other | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | See essential repairs \$ | |

Windows

| | | | | | |
|----------------------|-----|--------------------------|-----|--------------------------|----|
| Replace broken glass | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
|----------------------|-----|--------------------------|-----|--------------------------|----|

| | | | | | |
|------------------------|-----|--------------------------|-----|--------------------------|----|
| Repair or replace sash | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
|------------------------|-----|--------------------------|-----|--------------------------|----|

Doors

| | | | | | | |
|-------------------------|-----|--------------------------|-----|-------------------------------------|----|---------------|
| Repair or replace doors | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 400.00 |
|-------------------------|-----|--------------------------|-----|-------------------------------------|----|---------------|

| | | | | | | |
|-------------------------------|-----|--------------------------|-----|-------------------------------------|----|--------------|
| Repair or repl. locks/latches | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 50.00 |
|-------------------------------|-----|--------------------------|-----|-------------------------------------|----|--------------|

Walls/Ceilings

| | | | | | | |
|-----------------------------|-----|--------------------------|-----|-------------------------------------|----|-----------------|
| Repair or repl. @ defective | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 2,000.00 |
|-----------------------------|-----|--------------------------|-----|-------------------------------------|----|-----------------|

Paint

| | | | | | | |
|-----------------------------|-----|--------------------------|-----|-------------------------------------|----|-----------------|
| Repair or repl. @ defective | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 1,000.00 |
|-----------------------------|-----|--------------------------|-----|-------------------------------------|----|-----------------|

Fire Safety

| | | | | | |
|------------------------------|-----|--------------------------|-----|--------------------------|----|
| Install smoke/CO alarm:bsmt. | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
|------------------------------|-----|--------------------------|-----|--------------------------|----|

| | | | | | |
|----------------------------------|-----|--------------------------|-----|--------------------------|----|
| Install smoke/CO alarm: 1st flr. | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
|----------------------------------|-----|--------------------------|-----|--------------------------|----|

| | | | | | | |
|----------------------------------|-----|--------------------------|-----|-------------------------------------|----|--------------|
| Install smoke/CO alarm: 2nd flr. | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 75.00 |
|----------------------------------|-----|--------------------------|-----|-------------------------------------|----|--------------|

Handrails

| | | | | | | |
|--------------------------|-----|--------------------------|-----|-------------------------------------|----|---------------|
| Repair/replace defective | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 250.00 |
|--------------------------|-----|--------------------------|-----|-------------------------------------|----|---------------|

Stairs

| | | | | | | |
|------------------|-----|--------------------------|-----|-------------------------------------|----|---------------|
| Repair defective | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 150.00 |
|------------------|-----|--------------------------|-----|-------------------------------------|----|---------------|

Floors

| | | | | | | |
|------------------|-----|--------------------------|-----|-------------------------------------|----|-----------------|
| Repair defective | n/a | <input type="checkbox"/> | Yes | <input checked="" type="checkbox"/> | \$ | 2,000.00 |
|------------------|-----|--------------------------|-----|-------------------------------------|----|-----------------|

Other

| | | | | | |
|--|-----|--------------------------|-----|--------------------------|----|
| | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
|--|-----|--------------------------|-----|--------------------------|----|

| | | | | | |
|--|-----|--------------------------|-----|--------------------------|----|
| | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
|--|-----|--------------------------|-----|--------------------------|----|

| | | | | | |
|--|-----|--------------------------|-----|--------------------------|----|
| | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
|--|-----|--------------------------|-----|--------------------------|----|

| | | | | | |
|--|-----|--------------------------|-----|--------------------------|----|
| | n/a | <input type="checkbox"/> | Yes | <input type="checkbox"/> | \$ |
|--|-----|--------------------------|-----|--------------------------|----|

| | | |
|----------------------------------|----|-----------------|
| Interior: Estimated Cost: | \$ | 7,265.00 |
|----------------------------------|----|-----------------|

| | | |
|---|----|------------------|
| Total Exterior and Interior Cost:* | \$ | 42,680.00 |
|---|----|------------------|

*average contracted cost. Actual costs may vary. Self help will reduce the amount.

Inspected by: Jeff Sporer

Date: 2/26/2018

Self Help

Work listed as "self help" means the cost estimate includes only the cost of the materials, not labor or equipment.

Important Information Regarding Permits

All plumbing, heating, electrical, and structural repairs require permits before work can start.

Permits are obtained at the Development Center located on the first floor of 809 N. Broadway.

Licensed contractors must do the above work, although owner occupants *may* be eligible to do maintenance work and structural/carpentry repairs.

Owner occupants *may* be eligible to do plumbing work on the unit they live in, but check with the plumbing inspector first.

Generally, minor carpentry repairs, plaster patching, and painting do not require permits.

Anyone disturbing painted surfaces must assume they contain lead paint if the home was built before 1978. Contractors must be licensed to do lead abatement and must obtain a permit. Permits are obtained from the Health Department, located at 7630 W. Mill Road.